

SECTION 07 4210.11

COMPOSITE METAL HYBRID (CMH) SUB-FRAMING CLIP SYSTEM

PART 1 - GENERAL

1.01 SECTION INCLUDES

- A. Composite Metal Hybrid (CMH) sub-framing clip system with in-fill insulation integrated with [metal wall panels] [brick veneer] [CMU veneer] [phenolic panels] [fiber cement panels] [terracotta] or [< ____ >] exterior wall cladding.
 - 1. Substrate: [Exterior sheathing over metal stud framing] [Exterior sheathing over wood stud framing] [Concrete masonry units (CMU)] or [Poured concrete].

1.02 RELATED REQUIREMENTS

- A. Section 03 3000 – Cast-in-Place Concrete: Concrete wall substrate
- B. Section 04 2000 – Unit Masonry: Concrete masonry unit (CMU) wall substrate
- C. Section 05 4000 – Cold-Formed Metal Framing: Metal stud substrate support framing
- D. Section 06 1000 – Rough Carpentry: Exterior sheathing and wood stud substrate support framing
- E. Section 07 2500 – Weather Barriers: Air, water, vapor barrier at exterior wall
- F. Section 07 4200 – Wall Panels: Wall cladding system
- G. Section 07 9200 – Joint Sealants: Perimeter sealant
- H. Section 09 2116 – Gypsum Board Assemblies: Exterior sheathing

1.03 REFERENCE STANDARDS

- A. ASCE American Society of Civil Engineers (www.asce.org)
 - 1. ASCE 7 – Minimum Design Loads for Buildings and Other Structures; 2016 with Supplements and Errata
 - 2. ASCE – Structural Plastics Design Manual
- B. ASHRAE American Society of Heating, Refrigerating, and Air-Conditioning Engineers (www.ashrae.org)
 - 1. ASHRAE 90.1 – Energy Standard for Buildings Except Low-Rise Residential Buildings; 2019
 - 2. ASHRAE 189.1 – Standard for the Design of High-Performance Green Buildings Except Low-Rise Residential Buildings; 2017
- C. ASTM International (American Society for Testing and Materials; www.astm.org)
 - 1. ASTM A653/A653M – Standard Specification for Steel Sheet, Zinc-Coated (Galvanized) or Zinc-Iron Alloy-Coated (Galvannealed) by the Hot-Dip Process; 2015
 - 2. ASTM C518 – Standard Test Method for Steady-State Thermal Transmission Properties by Means of the Heat Flow Meter Apparatus; 2015
 - 3. ASTM C553 - Standard Specification for Mineral Fiber Blanket Thermal Insulation for Commercial and Industrial Applications; 2013
 - 4. ASTM C612 - Standard Specification for Mineral Fiber Block and Board Thermal Insulation; 2014
 - 5. ASTM C754 - Standard Specification for Installation of Steel Framing Members to Receive Screw-Attached Gypsum Panel Products; 2015
 - 6. ASTM C1177/C1177M – Standard Specification for Glass Mat Gypsum Substrate for Use as Sheathing; 2013
 - 7. ASTM C1363 - Standard Test Method for Thermal Performance of Building Materials and Envelope Assemblies by Means of a Hot Box Apparatus; 2011
 - 8. ASTM C1396/C1396M – Standard Specification for Gypsum Board; 2014a
 - 9. ASTM D256 - Standard Test Methods for Determining the Izod Pendulum Impact Resistance of Plastics; 2010e1

PROJECT NO.:
DATE:

PROJECT NAME
PROJECT LOCATION

10. ASTM D570 – Standard Test Method for Water Absorption of Plastics; 2010e1
 11. ASTM D635 – Standard Test Method for Rate of Burning and/or Extent and Time of Burning of Plastics in a Horizontal Position; 2014
 12. ASTM D638 – Standard Test Method for Tensile Properties of Plastics; 2014
 13. ASTM D696 - Standard Test Method for Coefficient of Linear Thermal Expansion of Plastics Between minus 30 degrees C and 30 degrees C with a Vitreous Silica Dilatometer; 2008e1
 14. ASTM D695 – Standard Test Method for Compressive Properties of Rigid Plastics; 2015
 15. ASTM D790 – Standard Test Methods for Flexural Properties of Unreinforced and Reinforced Plastics and Electrical Insulating Materials; 2010
 16. ASTM D792 – Standard Test Methods for Density and Specific Gravity (Relative Density) of Plastics by Displacement; 2013
 17. ASTM D2583 - Standard Test Method for Indentation Hardness of Rigid Plastics by Means of a Barcol Impressor; 2013a
 18. ASTM D2842 - Standard Test Method for Water Absorption of Rigid Cellular Plastics; 2012
 19. ASTM D4385 - Standard Practice for Classifying Visual Defects in Thermosetting Reinforced Plastic Pultruded Products; 2013
 20. ASTM E84 – Standard Test Method for Surface Burning Characteristics of Building Materials; 2015a
 21. ASTM E96/E96M - Standard Test Methods for Water Vapor Transmission of Materials; 2015
 22. ASTM E283 - Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen; 04(2012)
 23. ASTM E2178 - Standard Test Method for Air Permeance of Building Materials; 2013
- D. IBC – International Building Code (International Code Council); 2018
- E. IECC – International Energy Conservation Code; 2018
- F. IgCC – International Green Construction Code; 2018
- G. NFPA – National Fire Protection Association (www.nfpa.org)
1. NFPA 285 – Standard Fire Test Method for Evaluation of Fire Propagation Characteristics of Exterior Non-Load-Bearing Wall Assemblies Containing Combustible Components; 2015
- H. Voluntary Product Standard; National Institute of Standards and Technology (NIST)
1. 1. PS 1 – Structural Plywood; 2009

1.04 ADMINISTRATIVE REQUIREMENTS

- A. Coordination: Coordinate construction of wall cladding support system over substrate indicated for proper drainage, flashing, trim, backup support, soffits, and other related Work.
1. Review and finalize the construction schedule.
 2. Verify availability of materials, installer's personnel, equipment, and facilities needed to maintain the schedule.
 3. Review means and methods related to installation, including manufacturer's written instructions.
 4. Examine support conditions for compliance with requirements, including alignment and attachment to structural support system.
 5. Review flashings, wall cladding details, wall penetrations, drainage plane, openings, and condition of other construction that affects this Work.
 6. Review temporary protection requirements for during and after installation of this Work.

1.05 SUBMITTALS

- A. See Section 01 3000 – Administrative Requirements for submittal procedures.
- B. Product Data: Submit for each type of product indicated; include construction details, material descriptions, dimensions of individual components and profiles, and accessories as necessary for a complete fully functioning and assembled system.
1. Continuous insulation support system attachment methods and required fasteners
 2. Wall-mounted items, including doors, windows, louvers, and lighting fixtures
 3. Wall penetrations, including pipes, electrical fixtures, and any other utilities

PROJECT NO.:
DATE:

PROJECT NAME
PROJECT LOCATION

- C. Test and Inspection Reports: Submit test and inspection reports on each type of wall cladding/veneer system based on evaluation of comprehensive tests performed by a nationally recognized testing agency.
- D. Warranty: Submit manufacturer warranty and ensure forms have been completed in the Owner's name and registered with the manufacturer.

1.06 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing the products specified in this section with at least three years of documented experience.
- B. Installer: Company specializing in performing Work of this section and the following:
 - 1. Install the system in strict compliance with manufacturer's installation instructions.
 - 2. Have not less than three years of documented experience.

1.07 DELIVERY, STORAGE, AND HANDLING

- A. Deliver materials to site in manufacturer's original unopened containers and packaging with labels clearly identifying product name and manufacturer.
- B. Deliver components and other manufactured items or accessories without damage or deformation.
- C. Storage: Store materials in clean, dry, and level interior areas or outdoor areas for limited duration in accordance with the manufacturer's written instructions.
- D. Protect components and auxiliary accessories during transportation, handling, and installation from moisture, excessive temperatures, and other construction operations in accordance with manufacturer's written instructions.
- E. Handle components in strict compliance with manufacturer's written instructions and recommendations and in a manner to prevent bending, warping, twisting, and surface, edge, or corner damage.

1.08 SITE CONDITIONS

- A. Weather Limitations: Proceed with installation only when existing and forecasted weather conditions permit assembly of this Work in accordance with manufacturer's written installation instructions and warranty requirements.

1.09 WARRANTY

- A. See Section 01 7800 - Closeout Submittals for additional warranty requirements.
- B. CMH Sub-Framing Clip System Warranty: Provide written warranty by manufacturer agreeing to correct defects in manufacturing within a **[five year]** or [>] period after Date of **[Delivery]** or **[Substantial Completion]**.

PART 2- PRODUCTS

2.01 MANUFACTURER

- A. Advanced Architectural Products (A2P): Composite Metal Hybrid (CMH) Sub-Framing Clip System Manufacturer:
 - 1. Address: 959 Industrial Drive, Allegan, Michigan 49010.
 - 2. Phone: (269) 355-1818; Fax: (866) 858-5568; Website: www.smartcisystems.com
 - 3. Other products shall be pre-submitted and approved products that meet materials and performance requirements with specified and validated third party testing.
 - 4. No post-bid substitutions permitted.

2.02 DESCRIPTION

- A. Attach CMH sub-framing clip system components [through exterior sheathing into metal stud framing] [through exterior sheathing into wood stud framing] [to concrete masonry units (CMU)] or [to poured concrete].

AUTHOR
FILE NAME

COMPOSITE METAL HYBRID (CMH) SUB-FRAMING CLIP SYSTEM
07 4210.11 - 3 of 8

PROJECT NO.:
DATE:

PROJECT NAME
PROJECT LOCATION

1. Refer to Section 05 4000 for metal stud framing.
 1. Refer to Section 06 1000 for **[exterior sheathing]** and/or **[wood stud framing]**.
 2. Refer to Section 03 3000 for concrete substrate.
 3. Refer to Section 04 2000 for CMU substrate.
- B. Install CMH sub-framing clip system components vertically through exterior sheathing into stud support system as indicated on drawings in compliance iwht specified requirements.
- C. Install CMH sub-framing clip system components vertically onto **[masonry]** or **[concrete]** substrate system with shims as indicated on drawings in compliance with specified requirements.
- D. Attached metal hat channel, mount horizontally to vertical CMH sub-framing clips, connecting adjacent clips in series to each other.

2.03 PERFORMANCE REQUIREMENTS

- A. System thermal Design: Ensure installed insulation and CMH sub-framing clip system, sub-framing, clips, and cladding attachment does not have thermal bridging of fasteners or framing that creates a continuous metal path from exterior surface of insulation to the interior face of insulation.
1. System thermal design shall meet or exceed thermal design requirements in compliance with **[ASHRAE 90.1]** **[ASHRAE 189.1]** **[IECC]** or **[IgCC]** energy code.
 2. Thermal Resistance: Wall assembly R-Value of [].
 3. Thermal Performance Test: Provide thermal resistance (R-value) indicated, in compliance with ASTM C1363, corrected to 15 mph outside and still air inside, with installed condition including fastening and joints.
 - a. Provide efficiency of no less than [93 to 98 percent] or [> percent], with a maximum temperature differential of 18 degrees F from interior wall surface to interior wall cavity and node locations with a 70 degrees F exterior to interior wall temperature delta.
 - c. Provide test unit with at least one insulation panel horizontal and vertical joint length and height of test chamber area.
 - d. Provide finite element analysis of three-dimensional simulation of described wall assembly sealed by a professional engineer in compliance with code performance requirements and exceeding it by at least 3 percent.
- B. Temperature: Comply with structural loading requirements within a service temperature range of minus 55 degrees Fahrenheit to 190 degrees F.
1. Submit the following tests at the high value (at least 190 degrees F) of the temperature:
 - a. Fastener pullout – ASTM D7332/D7332M
 - b. Tensile Strength – ASTM D638
 - i. Crosswise (CW)
 - ii. Lengthwise (LW)
 - c. Modulus of Elasticity – ASTM D638
 - i. Crosswise (CW)
 - ii. Lengthwise (LW)
 - d. Engineering calculations that include the following:
 - i. Point load calculations of the cladding attachment to the sub-framing
 1. Uniform loading not allowed.
 - ii. Include Live and Dead Load simultaneously modeled.
 - iii. Deflection meeting specified criteria.
 2. Performance criteria from high end of the service range to meet the minimum specified properties.
 3. Test reports must include data at high end elevated service temperatures (at least 190 degrees Fahrenheit) – if not included, submittal is not approved.
- C. Fire-Test-Response Characteristics: Provide composite metal hybrid (CMH) sub-framing clip system with fire-test results indicated as determined by test standard indicated and applied by UL or other testing and inspection agency acceptable to authorities having jurisdiction.
1. Surface Burning Characteristics: In compliance with ASTM E84, for foam insulation, composite metal hybrid and interior surfaces as follows:

AUTHOR
FILE NAME

COMPOSITE METAL HYBRID (CMH) SUB-FRAMING CLIP SYSTEM
07 4210.11 - 4 of 8

- a. Flame Spread Index (FSI): 25 or less.
- b. Smoke Developed Index (SDI): 450 or less.
2. Intermediate Scale Multistory Fire Test: Comply with NFPA 285 and/or IBC acceptance criteria for wall height above grade and fire separation distances when wall type and other noted conditions require such testing or compliance with requirements as indicated.

2.04 COMPOSITE METAL HYBRID (CMH) SUB-FRAMING CLIP SYSTEM

- A. CMH Sub-Framing Clip System: Provide CMH sub-framing clip system consisting of polyester resin matrix with recycled materials, fire retardant additives and reinforced with integral continuous metal inserts the length of profile at all fastening locations. Reinforce CMH sub-framing clip with glass strand rovings used internally for longitudinal (lengthwise) strength and continuous strand glass mats or stitched reinforcements used internally for transverse (crosswise) strength. Depth of Girt: [1-1/2 inch] [2 inch] [2-1/2 inch] [3 inch] [3-1/2 inch] [4 inch] [4-1/2 inch] [5 inch] [5-1/2 inch] [6 inch] or [8 inch] deep.
1. Length of Clip; GreenGirt: 6 inches long.
 2. Depth of Clip; GreenGirt: **[2 inch] [2-1/2 inch] [3 inch] [3-1/2 inch] [4 inch] [4-1/2 inch] [5 inch] [5-1/2 inch] or [6 inch]** deep.
 3. Grid Spacing of CMH Sub-Framing Clips; Horizontally & Vertically: **[16 by 32 inches] [16 by 24 inches] [24 by 24 inches] or [32 by 16 inches]**, with maximum area of 4 sq. ft. (576 sq. inches.)
 4. Provide continuous non-corrosive steel insert for engagement of fasteners, at least 16-gauge, 0.0598 inch (1.52 mm) thick with G90 galvanized coating designation in compliance with ASTM A653/A653M.
 - a. Anchor sub-girts and other wall cladding support accessories to steel insert set into and part of CMH.
 - b. Provide screw pullout testing that meets or exceeds [**<_____ lbs.>**].
 5. Provide integral compression seal in CMH sections to ensure insulation will not dislodge.
 6. Provide integral anti-siphon grooves on the exterior and interior flanges of CMH.
 7. Provide force distribution zones integrally designed into the profile of CMH.
 8. Surface Burning Characteristics:
 - a. Flame Spread Index (FSI): 25 or less, when tested in accordance with ASTM E84.
 - b. Smoke Developed Index (SDI): 450 or less, when tested in accordance with ASTM E84.
 9. Flammability: Comply with ASTM E84.
 10. Self-Extinguishing: Comply with ASTM D635.
 11. Profile Visual Requirements: Comply with ASTM D4385.
 12. Tensile Stress: Provide engineered lengthwise and crosswise tensile stress in compliance with performance loading criteria and specified safety factors, in accordance with ASTM D638.
 13. Compressive Stress: Provide engineered lengthwise and crosswise compressive stress in compliance with performance loading criteria and specified safety factors, in accordance with ASTM D695.
 14. Flexural Stress: Provide engineered lengthwise and crosswise flexural stress in compliance with performance loading criteria and specified safety factors, in accordance with ASTM D790.
 15. Modulus of Elasticity: Engineered to meet performance loading criteria and specified safety factors.
 16. Barcol Hardness: 45, in accordance with ASTM D2583.
 17. Water Absorption: Less than 0.46 percent by weight, within 24 hours, tested in accordance with ASTM D570.
 18. Density: Within range of 0.062 to 0.070 lbs./cubic inch, in accordance with ASTM D792.
 19. Lengthwise Coefficient of Thermal Expansion: 7.0×10^{-6} inch/inch/degrees F, in accordance with ASTM D696.
 20. Notched Izod Impact, Lengthwise: 24 ft lbs./inch, in accordance with ASTM D256 within temperature range indicated.
 21. Notched Izod Impact, Crosswise: 4 ft lbs./inch, in accordance with ASTM D256 within temperature range indicated.

2.05 INSULATION

- A. Mineral Fiber Board Insulation: Rigid or semi-rigid mineral fiber, ASTM C612 or ASTM C553.
1. Unfaced - Flame Spread Index: Zero (0) when tested in accordance with ASTM E84.
 2. Smoke Developed Index: Zero (0), when tested in accordance with ASTM E84.
 3. Board Size: **[16 by 48 inches] [24 by 48 inches] [36 by 48 inches] or [() by () inches]**.
 4. Board Thickness: **[2 inch] [2-1/2 inch] [3 inch] [3-1/2 inch] or [() inch]**.

PROJECT NO.:
DATE:

PROJECT NAME
PROJECT LOCATION

5. Thermal Resistance: R-Value of **[4.2]** or **[]** at 75 degrees F, minimum, when tested according to ASTM C518.
 6. Compressive Resistance: ASTM C612, **[Type IB, 25 psf]** **[Type II, 25 psf]** or **[Type III, 12 psf]**, minimum.
 7. Acceptable Products:
 - a. Johns Manville; Product MinWool Curtainwall (www.jm.com)
 - b. Thermafiber, Inc.; Product RainBarrier HD (www.thermafiber.com)
 - c. ROXUL, Inc; Product Roxul Plus Metal Building (www.roxul.com)
 - d. **[]**
 - e. Substitutions: See Section 01 6000 – Product Requirements
- B. Sprayed Polyurethane Foam (SPF) Insulation: Medium-density, rigid or semi-rigid, open or closed-cell polyurethane foam; foamed on-site, using blowing agent of water or non-ozone-depleting gas.
1. Conform to applicable code requirements for **[flame and smoke]** **[concealment]** or **[overcoat]** limitations.
 2. Thickness: **[2 inch]** **[2-1/2 inch]** **[3 inch]** **[3-1/2 inch]** or **[() inch]**.
 3. Thermal Resistance: R-Value of 5, minimum, when tested at 1-inch thickness in accordance with ASTM C518.
 4. Water Vapor Permeance: Maximum of 2 perms, tested at intended thickness in accordance with ASTM E96/E96M, desiccant method.
 5. Air Permeance: Maximum of 0.004 cfm/sq ft, tested at intended thickness in accordance with ASTM E2178 or ASTM E283 at 1.5 psf.
 6. Water Absorption: Maximum of 2 percent by volume, tested in accordance with ASTM D2842.
 7. Surface Burning Characteristics: Maximum flame spread index/smoke developed index of 25/450, tested in accordance with ASTM E84.
 8. Acceptable Products:
 - a. BASF Corporation; Product WALLTITE US (www.spf.basf.com)
 - b. Demilec LLC; Product HEATLOK SOY 200 (www.demilec.com)
 - c. Icynene Inc; Product ProSeal Eco (www.icynene.com)
 - d. **[]**
 - e. Substitutions: See Section 01 6000 – Product Requirements

2.06 ASSEMBLY

- A. Assemble CMH sub-framing clip system using manufacturer's standard procedures and processes identical to tested units and as necessary to comply with performance requirements indicated.
1. Comply with CMH sub-framing clip system and dimensional and structural requirements as indicated on drawings.
 2. Erect CMH sub-framing clip system in established sequence in accordance with manufacturer's standard installation procedures.
 3. Provide spray foam sealant on backside of cantilevered fasteners that completely puncture insulation layer.

2.07 ACCESSORIES

- A. Provide accessories necessary for complete CMH sub-framing clip system including **[metal closure trim]** **[transition angle]** **[strapping]** **[tie-in brackets]** or **[< >]** and similar items.
- B. Horizontal Hat Channels: **[()]** inch high with **[()]** inch flanges, **[16 gauge]** or **[18 gauge]** minimum thickness, hot dipped galvanized with standard G90 coating designation in compliance with ASTM A653/A653M.
- C. Fasteners: Corrosion-resistant, self-tapping and self-drilling screws, bolts, nuts, and other fasteners as recommended by CMH sub-framing clip system manufacturer for CMH material and project application.
1. Cladding to CMH: Use standard self-tapping metal screws.
 2. CMH to Metal Stud Wall Framing: Use standard self-tapping metal screws.
 3. CMH to Concrete/CMU: Use standard masonry or concrete screw anchors in predrilled hole.
 4. CMH to Wood Framing: Use standard wood screw anchors.
 5. DO NOT USE powder, air, or gas actuated fasteners or actuated fastener tools. DO NOT USE impact wrenches when fastening to or from the CMH.

PROJECT NO.:
DATE:

PROJECT NAME
PROJECT LOCATION

- D. Wall Sheathing: Plywood, PS 1, Grade C-D, Exposure I.
 - 1. Refer to drawings for thickness and Section 06 1000 for additional requirements.
- E. Wall Sheathing: Gypsum board, complying with requirements of ASTM C1396/C1396M for gypsum sheathing, V-shaped long edges, Type X fire-resistant.
 - 1. Refer to drawings for thickness and [Section 06 1000] or [Section 09 2116] for additional requirements.
- F. Wall Sheathing: Glass mat faced gypsum, ASTM C1177/C1177M, square long edges, Type X fire-resistant.
 - 1. Refer to drawings for thickness and [Section 06 1000] or [Section 09 2116] for additional requirements.
- G. Weather Resistant Barrier (WRB): Refer to Section 07 2500 for requirements.
- H. Sealants: Refer to Section 07 9200 for sealant information.

PART 3 - EXECUTION

3.01 EXAMINATION

- A. Examine substrates, areas of this Work, and project conditions with installer present for compliance with requirements for installation tolerances, substrates, CMH sub-framing clip system conditions, and other conditions affecting performance of this Work.
- B. Examine structural wall framing to ensure that angles, channels, studs, and other structural support members have been installed within alignment tolerances required by CMH sub-framing clip system manufacturer.
- C. Examine rough-in for components and systems penetrating CMH sub-framing clip system to coordinate actual locations of penetrations relative to CMH sub-framing clip systems joint locations prior to installation.
- D. Verify that mechanical and electrical services for exterior walls have been installed and tested and, if appropriate, verify that adjacent materials and finishes are dry and ready to receive insulation.
- E. Proceed with installation only after wall substrate surfaces have been properly prepared, and unsatisfactory conditions have been corrected.

3.02 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using methods recommended by CMH manufacturer for achieving the best result for substrate under project conditions.
- C. Prepare sub-framing, base angles, sills, furring, and other CMH sub-framing clip system members and provide anchorage in accordance with ASTM C754 for substrate type and wall cladding type in accordance with manufacturer's installation instructions.

3.03 INSTALLATION

- A. Install CMH sub-framing clip system in accordance with manufacturer's installation instructions.
- B. Install system to fill-in exterior spaces without gaps or voids, and do not compress insulation panels.
- C. Trim insulation neatly to fit spaces and insulate miscellaneous gaps and voids.
- D. Fit insulation tight in spaces and tight to exterior side of Mechanical/Electrical services within plane of insulation.
- E. Exposed insulation must be protected from open flame.
- F. Exterior wall insulation is not intended to be left exposed for extended periods of time without adequate protection.

PROJECT NO.:
DATE:

PROJECT NAME
PROJECT LOCATION

- G. Install CMH sub-framing clip system in compliance with system orientation, sizes, and locations as indicated on drawings.

3.04 TOLERANCES

- A. Shim and align CMH sub-framing clip system within installed tolerances of 1/4 inch in 20 feet, non-cumulative, level, plumb, and on location lines as indicated.

3.05 PROTECTION

- A. Protect installed products from damage until Date of Substantial Completion.
- B. Ensure that insulation panels are not exposed to moisture.
 - 1. Remove wet insulation panels or allow them to completely dry prior to installation of CMH sub-framing clip system.
- C. Replace damaged insulation prior to Date of Substantial Completion.

END OF SECTION